



दिल्ली मेट्रो रेल कॉर्पोरेशन लि० DELHI METRÔ RAIL CORPORATION LTD.

(A JOINT VENTURE OF GOVERNMENT OF INDIA AND GOVT. OF DELHI)

N.B.C.C. Place, Bhisma Pitamah Marg, Pragati Vihar, New Delhi-110003

30th September, 2008

M/S Dura Build Care Pvt. Ltd.
104 – 106, Dimension Deepti Plaza,
Plot No – 3, Pocket – 6,
Nasirpur, Dwarka,
New Delhi – 110075.

Kind Attn.: - **Mr. L. P. Bhattacharya. – General Manager (Mkt. & Admin.)**

Sub. : - **General approval of Dura Build Care products for DMRC projects.**

Dear Sir,

With reference to your letter of request dated 29th Aug, 2008 and 30th Sept, 2008 for including the name of "M/S Dura Build Care Pvt. Ltd". as approved vendor for supplying of Admixtures and Water proofing compounds for DMRC projects. We would like to mention that "M/S Dura Build Care Pvt. Ltd". have been considered by DMRC as an approved vendor for supplying of Admixtures and Water proofing compounds for our on going and upcoming projects on the basis of following grounds:

- (1) M/S Dura Build Care Pvt. Ltd. have already been supplying their products for AZADPUR and AKSHASDHAM Metro station on behalf of M/S Parasvath Developers Ltd vide letter of approval dated 29/05/2007 and 27/11/2008 respectively. Till date there are no adverse comments about your quality from the contractor, GC and site.
- (2) It is also noticed that M/S Dura Build Care Pvt. Ltd. have already supplied their Products in various Governmental and non Governmental projects and also an approved vendor in various Government departments like CPWD, PWD, DDA, NTPC etc.

Keeping in view of the above, M/S Dura Build Care Pvt. Ltd. is being considered as an approved vendor for DMRC projects subject to the quality of admixtures being maintained in terms of consistencies as per specification.

The Corporation will monitor and review the performance of your product (admixtures and waterproofing compounds) during execution by the site. The Corporation wholly reserves the rights to revoke/suspend the enlistment on the basis of review any time . Please note that this approval has been accorded on the condition of maintaining of quality intact. In case of any negative feedback and deterioration in quality, this approval will stand cancelled automatically. Mandatory checks about the quality will also be carried out as and when required so as to satisfy the site about the quality and the performance.

Please note that your admixtures for concrete water reducing and air entraining type (liquid form) shall be acceptable on the basis of BIS Certification from Bureau of Indian Standards confirming to IS-9103-1999. The other tests stipulated in table 1A & 1B are in any case to be carried out by an independent Laboratory as and when required.

Thanking you

Yours faithfully,



(Rajan Kataria)
Chief Engineer (Design)